



FLOOR PLAN - LIGHTING
SCALE : 1/4" = 1'-0"

- GENERAL NOTES:**
1. ALL EMERGENCY BATTERY UNITS SHALL BE TYPE "EBU" AND EXIT LIGHTING FIXTURES SHALL BE TYPE "X"
 2. AIM EMERGENCY LIGHTING FIXTURE HEADS IN DIRECTION OF PATH OF EGRESS.
 3. ALL 120V BRANCH CIRCUITS SHALL BE COPPER #12AWG WIRING UNLESS NOTED OTHERWISE.
 4. ALL CONDUITS SHALL BE RECESSED.
 5. BRANCH CIRCUIT CONDUIT AND WIRING SHALL BE ROUTED IN CEILING SPACE FOR MECHANICAL UNITS ON ROOF. THE ROUTING SHALL BE PARALLEL AND/OR PERPENDICULAR TO BUILDING STRUCTURAL JOIST AND SHALL BE SUPPORTED FROM STRUCTURAL MEMBERS.

- KEY NOTES:**
- 1 SIGN LIGHTING (W.P. JUNCTION BOX), PROVIDE A TIME CLOCK AND ROUTE BRANCH CIRCUIT VIA TIMECLOCK. COORDINATE INSTALLATION OF NEW SIGN WITH OWNER AND EXACT LOCATION WITH ARCHITECTURAL TRADES AND OWNER.
 - 2 EMERGENCY BATTERY UNITS TO BE MOUNTED AT APPROXIMATELY 7'-6" AFF, CEILING MOUNTED UNITS TO BE FLUSH WITH CEILING GRID. MOUNT EXIT SIGNS AT 12" ABOVE DOOR OPENING.
 - 3 EMERGENCY LIGHTING UNITS SHALL BE WIRED TO LOCAL LIGHTING CIRCUIT AHEAD OF ALL SWITCHING DEVICES.
 - 4 W.P. EMERGENCY LIGHTING REMOTE HEAD UNIT, REFER TO LIGHTING FIXTURE SCHEDULE
 - 5 COORDINATE LIGHTING FIXTURE (GENERAL LIGHTING AND EBU) LAYOUT WITH MECHANICAL TRADES WITHIN THE ENTIRE SCOPE OF WORK AREA.
 - 6 SUPPORT ALL ELECTRICAL EQUIPMENT AND WIRING (INCLUDING LOW VOLTAGE) IN ACCORDANCE WITH NEC ARTICLE 300-11, 725 THROUGH 830.
 - 7 INSTALL TYPE "OA" AT 8'-0" AFG AND ROUTE VIA PHOTOCELL ON, TIMECLOCK OFF VIA BRANCH CIRCUIT A-9
 - 8 DIMMER SWITCH SHALL BE BY AQUITY BRAND, VERTICAL SLIDER TYPE.

ELECTRICAL SHEET INDEX	
SHEET NUMBER	DESCRIPTION
E-1	FLOOR PLAN - LIGHTING
E-2	FLOOR PLAN - POWER & SYSTEMS
E-3	ELECTRICAL ONE LINE DIAGRAM, SPECS, & SCHEDULES
E-4	ELECTRICAL SCHEDULES



S. Aragonés Jr.

nature's finest

DAZ
ARCHITECTURAL DESIGN, INC.

COPYRIGHT DATE: 2019

CLIENT/PROJECT:
NATURE'S FINEST PROMISING CENTER
NORTH AVE. & E. GOODALE AVE.
BATTLE CREEK, MICHIGAN

DRAWN BY: S.D.
CHECKED BY: S.B.

SHEET INFORMATION:
FLOOR PLAN - LIGHTING

CAD FILE:
NATURES_FINEST.AEC

SITE PLAN APPROVAL SET: 08-14-19
BID SET: 08-14-19
PERMIT SET: 08-14-19
CONSTRUCTION SET:

COMPLETION DATE:
08-14-19

REVISIONS:

JOB NO.
180810

SHEET NO.
E-1