

GENERAL NOTES:
(APPLY TO THIS SHEET ONLY)

THE INTENTION OF THESE DRAWINGS IS TO SHOW SCHEMATIC INTENT ONLY.
COORDINATE EXACT DIMENSIONED LOCATION OF ALL DEVICES WITH ARCHITECTURAL

OF ALL DEVIC

- 2. ALL KITCHEN/BREAK ROOM RECEPTACLES SHALL BE GFCI PROTECTED AS REQUIRED.
- 3. ALL "GENERAL USE" RECEPTACLES SHALL BE BEIGE WITH BRUSHED ALUMINUM COVER PLATES UNLESS NOTED OTHERWISE.
- 4. ALL "ISOLATED GROUND" RECEPTACLES SHALL BE COLOR ORANGE WITH BRUSHED ALUMINUM COVER PLATES UNLESS NOTED OTHERWISE.
- 5. ALL HVAC EQUIPMENT SHALL BE PROVIDED WITH EXTERNAL DISCONNECT/SWITCH. IF NOT, PROVIDED WITH EQUIPMENT THEN EXTERNAL DISCONNECT/SWITCH IS SHOWN. HVAC EQUIPMENT IS ASSUMED TO BE PROVIDED WITH AN INTERNAL DISCONNECT BY DIVISION 15. COORDINATE WITH DIVISION 15 PRIOR TO PURCHASE OF EQUIPMENT.
- 6. COORDINATE EXACT LOCATION OF HVAC EQUIPMENT WITH DIVISION 15 PRIOR TO INSTALLATION.
- 7. ALL ELECTRICAL DEVICES LABELED AS 'EX' ARE EXISTING TO REMAIN AS IS UNLESS NOTED OTHERWISE.

LEGEND NOTES:

(APPLY TO THIS SHEET ONLY)

- EXISTING 200 AMP/3—POLE, 120/208—VOLT PANEL SHALL BE REMOVED. ALL EXISTING FEEDER CONDUIT AND CONDUCTORS SHALL BE EXTENDED/MODIFIED TO NEW PANEL 'LL1' LOCATION. ALL EXISTING BRANCH CIRCUITS (I.E. CONDUIT AND CONDUCTORS) SHALL BE REMOVED BACK TO POWER SOURCE. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR NEW PANEL TO OPERATE AS EXISTING.
- EXISTING 100 AMP/3-POLE, 120/208-VOLT SUB-PANEL AND WIRE GUTTER SHALL BE REMOVED. ALL EXISTING FEEDER CONDUIT AND CONDUCTORS SHALL BE REMOVED BACK TO POWER SOURCE. ALL EXISTING BRANCH CIRCUITS (I.E. CONDUIT AND CONDUCTORS) SHALL BE REMOVED BACK TO POWER SOURCE.
- PROVIDE CONNECTION OF EXHAUST FAN TO INTERLOCK WITH WALL MOUNTED LIGHT SWITCH. PROVIDE CONNECTION OF EXHAUST FAN TO LIGHTING CIRCUIT SERVING THIS ROOM/AREA
- PROVIDE 4" X 8" 3/8" COPPER GROUND BAR FOR GROUNDING OF VOICE/DATA EQUIPMENT. GROUND BAR SHALL BE INSTALLED 18" A.F.F. AND SUPPORTED BY FOUR STAND OFF INSULATORS. PROVIDE 1#2 COPPER CONDUCTOR FROM THE MAIN BUILDING ELECTRICAL GROUND TO THE GROUND BAR. REFER TO DETAIL 1/E0.1.
- 5 3/4" X 8' X LENGTH REQUIRED TELEPHONE PLYWOOD BACKBOARD. PROVIDE WITH 1#6G. IN 3/4"C. TO ABOVE ACCESSIBLE CEILING.
- PROVIDE CONNECTION OF EXISTING PNEUMATIC TUBING BLOWER(S) TO NEW PANEL 'LL1'. ALL EXISTING CONDUIT AND CONDUCTORS SHALL BE EXTENDED/MODIFIED TO NEW PANEL 'LL1'. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR A COMPLETE AND OPERABLE SYSTEM.
- PROVIDE CONNECTION OF EXISTING JUNCTION BOXES FOR OPEN/CLOSE SIGNS TO NEW PANEL 'LL1'. ALL EXISTING CONDUIT AND CONDUCTORS SHALL BE EXTENDED/MODIFIED TO NEW PANEL 'LL1'. PROVIDE CONNECTION OF EXISTING OPEN/CLOSE SIGNS TO NEW WALL MOUNTED SWITCHES LOCATED IN TELLER AREA AS INDICATED ON SHEET E2.1. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR A COMPLETE AND OPERABLE SYSTEM.

- RELOCATE EXISTING (1) 4" CONDUIT FOR MAIN TELEPHONE SERVICE. EXTEND/MODIFY EXISTING CONDUIT UNDERGROUND AS REQUIRED TO NEW LOCATION AS INDICATED. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY CONNECTIONS FOR A COMPLETE AND OPERABLE SYSTEM.
- 9 EXISTING JUNCTION BOX FOR NIGHT DEPOSIT SHALL REMAIN AS IS. ALL EXISTING BRANCH CIRCUIT FEEDERS ASSOCIATED WITH NIGHT DEPOSIT SHALL BE REMOVED BACK TO POWER SOURCE. PROVIDE ALL NEW BRANCH CIRCUIT FEEDERS AS IINDICATED. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR A COMPLETE AND OPERABLE SYSTEM.
- EXISTING 200 AMP DISCONNECT SHALL BE REMOVED AND REPLACED WITH NEW 400 AMP DISCONNECT. EXISTING CONDUITS SHALL BE REMOVED BACK TO POWER SOURCE. EXISTING CONDUCTORS SHALL BE UTILIZED FOR NEW SERVICE. REFER TO RISER DIAGRAM 3/E1.1. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR NEW DISCONNECT TO OPERATE AS EXISTING.
- OUTLET AND SWITCHES FOR CUSTOMER TWO—WAY CCTV CAMERAS. PROVIDE 20/2 CABLING FROM EACH PLUG IN TRANSFORMER AND EACH SWITCH TO CUSTOMER UNIT VIA CONDUIT PROVIDE FOR CUSTOMER UNIT. OUTLETS TO BE SPACED MINIMUM 4" HORIZONTALLY AND 6" VERTICALLY.
- PROVIDE WALL MOUNTED JUNCTION BOX FOR ATM. COORDINATE EXACT LOCATION WITH ARCHITECT PRIOR TO INSTALLATION. COORDINATE EXACT POWER REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO INSTALLATION. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY WIRING FOR A COMPLETE AND OPERABLE SYSTEM.


KDA Holdings
Building on Ideas

Warner Summers Ditzel

Ditzel
Benefield
Ward & Associate
ARCHITECTURE PARK DRIVE ATLANTA, GA

WSDBW NO. 06091

FAIRWINDS



Date Rev. Description

3/30/07 C.D. Presentation

5/25/07 Coordination Set

KDA
Project (BWA - 07004)
Number: 27-0001
Drawn By: DSW
Checked By: CMV
Scale: AS NOTED

FLOOR PLAN -ELECTRICAL

F1 1